

CERTIFICATE OF COMPLIANCE

Certificate Number 20130729 – E31519
Report Reference E31519 - 20091119
Issue Date 2013-July-29

Issued to: SIEMENS AG
I IA CE CP R&D-VI 4
WERNER-VON-SIEMENS-STRASSE 48
92220 AMBERG, GERMANY

**This is to certify that
representative samples of**

Auxiliary Devices


Type No. 3RH29 followed by 1 or 2, followed by 1 or 6, followed by -1, -2 or -4, followed by A, B, D, E, F, G, H, L, M, N or X, followed by A, B, C, E or F, followed by 0, 1, 2, 3 or 4, followed by 0, 1, 2, 3 or 4, may be followed by numbers and/or characters. (See following page for additional model information.)

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: ANSI/UL 508, "Industrial Control Equipment" and CSA-C22.2 No. 14, "Industrial Control Equipment"

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus



CERTIFICATE OF COMPLIANCE

Certificate Number 20130729 – E31519
Report Reference E31519 - 20091119
Issue Date 2013-July-29

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Additional Model Information:

General:

These devices are 1, 2 or 4 pole auxiliary contact blocks for this manufacturer's devices series 3RT2 or 3RH2.

Ratings:

Laterally mounted versions

A600/Q600

10A / 240 V ac, general purpose

6A, 24 V dc, Pilot Duty

Front mounted versions

A600/Q600

10A / 240 V ac, general purpose

6A, 24 V dc, Pilot Duty

Solid-state compatible versions

0.1A / 240 V ac, general purpose

0.3A / 60 V dc



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus



CERTIFICATE OF COMPLIANCE

Certificate Number 20130729 – E31519
Report Reference E31519 - 20091119
Issue Date 2013-July-29

NOMENCLATURE BREAKDOWN:

3RH29 1 1 - 1 A A 0 0 -
I II III IV V VI VII VIII IX

I. 3RH29 - Accessories

- II. Suitable for contactor and contactor relay sizes
 - 1 - Front mounted versions suitable for devices 3RT2 and 3RH2
Laterally mounted versions for devices 3RT2 and 3RH2
 - 2 - Laterally mounted versions for devices 3RT2
- III.
 - 1 - Accessories, auxiliary contact blocks
 - 6 - Accessories, auxiliary contact blocks for use in specific IEC applications

- IV. Type of terminals
 - 1 - Screw terminal
 - 2 - Spring terminal
 - 4 - Ring lug terminal (wire binding screw)

- V. Design
 - A - Front mounted, 1 pole, entry of conductors top
 - B - Front mounted, 1 pole, entry of conductors bottom
 - D - Laterally mounted, 2 pole
 - E - Laterally mounted, 2 pole
 - F - Front mounted, 4 pole
 - G - Front mounted, 4 pole
 - H - Front mounted, 4 pole
 - L - Front mounted, 2 pole, entry of conductors top
 - M - Front mounted, 2 pole, entry of conductors bottom
 - N - Front mounted, solid-state compatible
 - X - Manufacturer's version

- VI. Switching function
 - A - Standard switching
 - B - Make-before-break, 1 NO/NC contact pair
 - C - Make-before-break, 2 NO/NC contact pairs
 - E - Laterally mounted, solid-state compatible
 - F - Front mounted, solid-state compatible



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus



CERTIFICATE OF COMPLIANCE

Certificate Number 20130729 – E31519
Report Reference E31519 - 20091119
Issue Date 2013-July-29

NOMENCLATURE BREAKDOWN (Cont.):

VII. Contact arrangement NO

- 0 - Non NO
- 1 - 1 NO
- 2 - 2 NO
- 3 - 3 NO
- 4 - 4 NO

VIII. Contact arrangement NC

- 0 - Non NC
- 1 - 1 NC
- 2 - 2 NC
- 3 - 3 NC
- 4 - 4 NC

IX. – Suffix letters and/or numbers specifies commercial variation



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

