

中国国家强制性产品认证证书

证书编号: 2004010305117280

委托人名称、地址

爱福门电子有限公司
Friedrichstr. 1, 45128 Essen, Germany

生产者(制造商)名称、地址

爱福门电子有限公司
ifm-Str. 1, 88069 Tett nang, Germany

生产企业名称、地址

爱福门电子有限公司
ifm-Str. 1, 88069 Tett nang, Germany

产品名称和系列、规格、型号

电容式接近开关

型号: KB, KG, KI 额定工作电压(Ue): 10V~55VDC、20V~250VAC/DC、30V~250VAC/20V~250VDC 额定动作距离(Sn): 5mm、8mm、10mm、12mm、15mm、20mm 操作频率(f): 10Hz、20Hz、25Hz、40Hz、50Hz 具体型号详见附录

产品标准和技术要求

GB/T 14048.10-2008

上述产品符合强制性产品认证实施规则
CNCA-01C-011: 2007的要求, 特发此证。

发证日期: 2010年10月28日 有效期至: 2015年10月25日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2004年05月18日

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询




主任:

中国质量认证中心

中国·北京·南四环西路188号9区 100070

<http://www.cqc.com.cn>





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2004010305117280

NAME AND ADDRESS OF THE APPLICANT

ifm electronic gmbh
Friedrichstr. 1, 45128 Essen, Germany

NAME AND ADDRESS OF THE MANUFACTURER

ifm electronic gmbh
ifm-Str. 1, 88069 Tettang, Germany

NAME AND ADDRESS OF THE FACTORY

ifm electronic gmbh
ifm-Str. 1, 88069 Tettang, Germany

NAME, MODEL AND SPECIFICATION

Proximity switch

型号: KB, KG, KI 额定工作电压(Ue):10V~55VDC、20V~250VAC/DC、30V~
250VAC/20V~250VDC 额定动作距离(Sn):5mm、8mm、10mm、12mm、15mm、20mm 操作
频率(f):10Hz、20Hz、25Hz、40Hz、50Hz 具体型号详见附录

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.10-2008

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification(REF NO. CNCA-01C-011:2007).

Date of issue: Oct. 28, 2010 Date of expiry: Oct. 25, 2015

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original certification: May. 18, 2004

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao




CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P.R. China

<http://www.cqc.com.cn>

Q 0312740



中国国家强制性产品认证证书

附录:

第 1 页 共 2 页

证书编号: 2004010305117280

纸号: 312740

序号	产品型号 Type designation	额定电压 Rated voltage(V)	额定电流 Rated current (mA)	动作距离 S _n (mm)	操作频率 Switching frequency / Hz	操作方式 characteristic
1	KB-2020-ABOA/NI	20...250 AC/DC	250 /200	20	25 AC / 40 DC	Integral leads
2	KB-2020-ABOA/NI/xm	20...250 AC/DC	250 /200	20	25 AC / 40 DC	Integral leads
3	KB-2020-BBOA/NI	20...250 AC/DC	250 /200	20	25 AC / 40 DC	Integral leads
4	KB-2020-BBOA/NI/xm	20...250 AC/DC	250 /200	20	25 AC / 40 DC	Integral leads
5	KB-3020-BNKG/NI/OBVZ/ SN5mm/xm/AMP	10...55 DC	250	5	40	plug-in
6	KB-3020-BNKG/OBVZ/ SN5mm	10...55 DC	250	5	40	Integral leads
7	KI-2015-ABOA/NI	20...250 AC/DC	250 /200	15	25 AC / 40 DC	Integral leads
8	KI-2015-ABOA/NI/xm	20...250 AC/DC	250 /200	15	25 AC / 40 DC	Integral leads
9	KI-2015-ABOA/NI/xm/LS	20...250 AC/DC	250 /200	15	25 AC / 50 DC	plug-in
10	KI-2015-BBOA/NI	20...250 AC/DC	250 /200	15	25 AC / 40 DC	Integral leads
11	KI-2015-BBOA/NI/xm	20...250 AC/DC	250 /200	15	25 AC / 40 DC	Integral leads
12	KI-2015-BBOA/NI/xm/LS	20...250 AC/DC	250 /200	15	25 AC / 50 DC	plug-in
13	KI-2015-FBOA/NI/SS	20...250 AC/DC	250 /200	15	25 AC / 40 DC	plug-in
14	KI-2015-FBOA/NI/SS/xm	20...250 AC/DC	250 /200	15	25 AC / 40 DC	plug-in
15	KIE2015-FBOA/NI	20...250 AC/DC	250 /200	15	25 AC / 40 DC	terminal
16	KIE2015-FBOA/NI/3D	20...250 AC/DC	250 / 130	15	25 AC / 50 DC	terminal
17	KIE3015-FPKG/NI	10...55 DC	250	15	40	terminal
18	KIE3015-FPKG/NI/55V/US	10...55 DC	250	15	40	plug-in
19	KG-2120NFBOAP2T/LS100	20...250 VDC 30...250 VAC	150/100	12	10	plug-in
20	KI-2200NFBOAP2T/LS100	20...250 VDC 30...250 VAC	150/100	20	10	plug-in

注: 此附录与证书同时使用时有效。




主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>





中国国家强制性产品认证证书

附录:

第 2 页 共 2 页

证书编号: 2004010305117280

纸号: 312740

21	KG-2008-ABOA/NI	20...250 AC/DC	150AC/100DC	8	25 AC / 50 DC	Integral leads
22	KG-2008-ABOA/NI/xm	20...250 AC/DC	150AC/100DC	8	25 AC / 50 DC	Integral leads
23	KG-2008-BBOA/NI	20...250 AC/DC	150AC/100DC	8	25 AC / 50 DC	Integral leads
24	KG-2008-BBOA/NI/xm	20...250 AC/DC	150AC/100DC	8	25 AC / 50 DC	Integral leads
25	KG-2008-FRKG/NI	10...55 DC	400/250	8	50	Integral leads
26	KG-2008-FRKG/NI/xm	10...55 DC	400/250	8	50	Integral leads
27	KGE2008-FBOA/NI	20...250 AC/DC	150AC/100DC	8	25 AC / 50 DC	terminal
28	KGE2008-FRKG/NI	10...55 DC	400/200	8	50	terminal

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

